



## ALLIED MOULDED PRODUCTS, INC.

222 N. Union St.  
Bryan, Ohio 43506-1450  
Phone 419-636-4217  
Fax: 419-636-2450  
www.alliedmoulded.com



### Manufactured Housing/Old Work Round Outlet Boxes with "S" Snap Brackets

#### Part Numbers **PC223OW**

1. Cut a 3 5/8" diameter circular hole in the wall or ceiling to comply with NEC 314-20. The box diameter is nominally 3 1/2" and the 3 5/8" diameter hole allows 1/16" clearance around the outside of the box.
2. Insert box into opening. Bracket will automatically compress and snap back into position. Tighten snap bracket screws until bracket is drawn snug to the back of the wallboard. UL<sup>®</sup> has tested these boxes in 3/8" thick plywood which is the substrate used for their standard test. The strength of the substrate must be equal to 3/8" thick plywood.
3. If the wall assembly is not accessible from the back side to complete the wiring, the wires must be secured to the box with speed "K" klamps before installing the box in the wall assembly.

Thomas D. Knecht  
Technical Service Manager

1-30-07