

CERTIFICATE OF COMPLIANCE

Certificate Number 20170508-E120175
Report Reference E120175-19890313
Issue Date 2017-MAY-08

Issued to: ALLIED MOULDED PRODUCTS INC
222 N UNION ST
BRYAN OH 43506-1450

This is to certify that representative samples of INDUSTRIAL CONTROL PANELS
Cat. Nos. AM-664, -864, -1084, -1086, -1206, -1224 -1226, -1426, -1648, -1868, -2068, -24200, -24208, -24240, -24248, -30240 or -30248, followed by -H, -T or blank, may be followed by -R, L or P, may be followed by -W.

Heavy Duty: Cat. No. AMHD, followed by 1860; followed by blank, H, L or T; followed by blank, R or W; may be followed by F.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 50, Enclosures for Electrical Equipment
UL 50E, Enclosures for Electrical Equipment, Environmental Considerations
UL 508A, Industrial Control Panels
UL 2043, Fire Test for Heat and Visible Smoke Release for Discrete Products and Their Accessories Installed in Air-Handling Spaces
CSA-C22.2 No. 94.2, Enclosures for Electrical Equipment, Environmental Considerations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

