



333 Plingsten Road
Northbrook, Illinois 60062-2096
(847) 272-8800
FAX No. (847) 272-8129
MCI Mail No. 254-3343
Telex No. 6502543343

June 26, 1996



Allied Moulded Products, Inc.
Attn: Mr. Thomas D. Knecht
222 N. Union St.
P O BOX 587
Bryan, OH 43506

Our Reference: File E 30594,

Subject: Use of Nonmetallic Clamp to Close the Opening of a Removed Knockout

Dear Mr. Knecht,

This letter will confirm our recent telephone conversation concerning the above subject.

You asked if the nonmetallic "K clamp" can be use to close the opening left by the removal of the knockout. The nonmetallic "K clamp" provided with your nonmetallic outlet boxes is the equivalent of the wall of the box and can be used to close the opening left by the removal of the knockout.

If you have any questions or need further information , please contact me.

Very truly yours,

A handwritten signature in cursive script that reads 'George Walbrecht'.

George Walbrecht (Ext. 43126)
Senior Project Engineer
Engineering Services, 413J

A not-for-profit organization
dedicated to public safety and
committed to quality service